



**West Des Moines Fire Department
FIRE PREVENTION BUREAU
(515) 273-0643**

UNATTENDED FUEL DISPENSING
WDM Fire Code

Provide an emergency shut off switch located within 100 feet of, but not less than 20 feet from the fuel dispensers. It shall be manually resettable.

Dispenser operating instructions shall be conspicuously posted in an approved location.

An emergency procedure sign shall be conspicuously posted in an approved location above the dispenser and above the emergency shut off.

The dispenser sign size shall be a minimum of 6 x 8 inches, red letters on white background to read:

In Case of Fire, Spill or Release (1/2" in height)

1. Use emergency shut off on (location) of building. **(3/8" in height)**
2. Report accident and dial 911. **(3/8" in height)**
3. Fire extinguisher located on (location) of building. **(3/8" in height)**
4. Address _____ **(3/8" in height)**

The emergency shut off sign size shall be a minimum of 8 x 10 inches red letters on white background to read:

EMERGENCY (1 1/2" in height)

FUEL SHUTDOWN (1 1/2" in height)

DEVICE (1 1/2" in height)

Mount a 20# ABC (60 BC) fire extinguisher in a cabinet with easily identifiable markings for fire extinguisher inside. Cabinet to be located within 75 feet of dispensers.

For additional information, please contact the Fire Marshal at 515-273-0643.

